



RESEARCH, DEVELOPMENT AND TESTING
NATIONAL INSTITUTE FOR
ELECTRICAL ENGINEERING
ICMET CRAIOVA

acreditat pentru
ÎNCERCARE



SR EN ISO / CEI 17025: 2005
CERTIFICAT DE ACREDITARE
nr. LI 529 / 2007

LABORATORIES DEPARTMENT
HIGH VOLTAGE DIVISION - HVD
Low Voltage Laboratory

Address: Calea Bucuresti No.144, 200515 Craiova, ROMANIA
Matriculation certificate: J 16/312/1999; Fiscal code: RO3871599
Phone: + 40 0351 402425, 404888; Fax: + 40 0251 415482, 0351 404890
www.icmet.ro, e-mail: testing_services@icmet.ro, ljt@icmet.ro

TYPE TEST REPORT No. 20065 / 07.08.2009

- | | |
|----------------------------|--|
| 1. CUSTOMER: | PANEL ELEKTRIK SAN VE TIC LTD. ŞTI |
| 2. CUSTOMER'S ADDRESS: | Org. San. Böl.17. Cad. No.27 Yakapinar/ADANA/TURKEY |
| 3. MANUFACTURER: | PANEL ELEKTRIK SAN VE TIC LTD. ŞTI |
| 4. MANUFACTURER'S ADDRESS: | Org. San. Böl.17. Cad. No.27 Yakapinar/ADANA/TURKEY |
| 5. TESTED PRODUCT: | 36 kV, 630A, Transformer Protection Switchgear with Circuit Breaker, serial no. 04-2009-0004 |
| 6. REFERENCE STANDARD: | IEC 62271-200:2003 |
| 7. TESTS PERFORMED: | Dielectric tests on auxiliary and control circuits |
| 8. TEST DATE: | 06.08.2009 |
| 9. TEST RESULT: | The product PASSED the tests. |

This report contains 5 pages and it is edited in 4 copies from which 3 copies for customer.

Head of High Voltage Division,
Eng. Ion PĂTRU



Head of Laboratory,
Eng. Aurelia SCORNEA

WARNINGS:

- The results refer to the tested product only.
- Publication or reproduction of the contents of this report in any other form, unless its complete photocopying, is not allowed without writing approval of the division to which laboratory belong to.
- Accreditation of the laboratory or any of its test reports issued under accreditation regime do not constitute or do not imply themselves an approval of the product by the accreditation body.
- All signatures from the present report are originals.
- The product was presented to be tested by the customer.



CONTENT:

Identification of the tested product (serial no, type).....	Page 3
Technical characteristics (established by manufacturer)	Page 3
Tests program	Page 3
Responsible for tests.....	Page 3
Dielectric tests on auxiliary and control circuits	Page 4
Annex 1	Page 5

IDENTIFICATION OF THE TESTED PRODUCT:

Tested product: 36 kV, 630A, Transformer Protection Switchgear with Circuit Breaker

Type: MMMH 36-04

Serial number / year: 04-2009-0004 / 2009

Technical specification/drawing: presented in Annex 1

Photo of the product: presented in Figure 1

Contract No.: 2266/01.06.2009

Product receiving date: 05.08.2009

Product condition at receiving: New



Figure 1: Tested product

TECHNICAL CHARACTERISTICS ESTABLISHED BY MANUFACTURER:

Rated voltage: 36 kV

Rated operating current: 630 A

Frequency: 50 Hz

Arc test current and duration: 16kA/1s

Rated supply voltage for auxiliary and control circuits: 24V DC / 220V AC

TESTS PROGRAM:

Dielectric tests on auxiliary and control circuits

RESPONSIBLE FOR TESTS: Eng. Ion DINU 

**DIELECTRIC TESTS ON AUXILIARY AND CONTROL CIRCUITS**

1. **Product receiving date:** 05.08.2009
2. **Test date:** 06.08.2009
3. **Reference standard:** IEC 62271-105:2002
4. **Atmospheric conditions:** $t = 26.2^{\circ}\text{C}$, $\text{RH} = 48.5\%$
5. **Equipment used:**
 - Generator hybrid for impulse voltage, negative polarity and alternative voltage type SIP010, serial no. 620091, manufactured by RFT Germany, calibration certificate no. 167(-)/14.10.2008, expanded uncertainty $U=4.5\%$ for alternative voltage for coverage factor $k=2$
 - Thermohygrometer type HD 100, serial no. 06102402, manufactured by KIMO, France, calibration certificate no. Dj 011-055 0482/ 2009, expanded uncertainty $U=0.3^{\circ}\text{C}$ for temperature measurement and $U=2\%$ for relative humidity for coverage factor $k=2$

6. Working procedure

The dielectric tests on auxiliary and control circuits were performed according to IEC 62271-105:2002, clause 6.2.10.

Auxiliary and control circuits of the switchgear and controlgear were subjected to short-duration power-frequency withstand tests between the auxiliary and control circuits connected together as a whole and the frame of the switching device, connected to the earth.

The test voltage of 2 kV, 50 Hz was applied for duration of 1 min.



Figure 2: Auxiliary and control circuits



Figure 3: Dielectric tests on auxiliary and control circuits

7. **Responsible for tests:** Eng. Ion DINU 

8. Test result

The product passed the test.

During the tests above, there were not disruptive discharges.



Annex 1

